

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1260289

Product: Electrical insulating matting

Type: DEK4-S7-1

Rating: class 4

Ordering firm: BOGUMA, s. r. o.
Továrenská 314, 95618 Bošany, Slovakia

Manufacturer: BOGUMA, s. r. o.
Továrenská 314, 95618 Bošany, Slovakia

Trade mark:

The test results are stated in the test-report No.: 261550-01/01 of: 28.07.2026

A sample of the product was found to be in conformity with:
ČSN EN 61111:2010 (idt. IEC 61111:2009)
cl. 5.2.2, 5.2.3, 5.2.5, 5.3, 5.5.2, 5.5.3, 5.6.2.2, 5.6.4.2, 5.7, 5.8.1, 5.8.2

Other data:

The validity of the certificate is limited to: 28.07.2029

29.07.2026

Prague

stamp and sign.

Mgr. Miroslav Sedláček
Head of Certification Body



261550-01